

OUTAGE LOG • 2022

OUTAGE REPORT	DATE	TIME	OUTAGE AREA	SYSTEM CATEGORY	OUTAGE CAUSE	CAUSE DETAIL	CUSTOMERS INTERRUPTED (CI)	CUSTOMER MINUTES OF INTERRUPTION (CMI)	SAIFE (#)	SAIDE (M)	CAIDE (M)	MAJOR EVENT
OR	1/2/2022	8:30 AM	LC-2	DISTRIBUTION OVERHEAD	EQUIPMENT	CONNECTOR	20	1960	0.00115	00	98	
OR (2)	1/2/2022	12:35 PM	LP-3	DISTRIBUTION OVERHEAD	EQUIPMENT	CONNECTOR	1	60	0.00006	00	60	
OR (3)	1/2/2022	9:35 PM	SS-3	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	25	19925	0.00143	01	797	
OR (4)	1/3/2022	10:52 AM	SS-2	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	3	174	0.00017	00	58	
OR (5)	1/9/2022	1:20 AM	WJ-2	DISTRIBUTION UNDERGROUND	EQUIPMENT	CUTOUT	8	720	0.00046	00	90	
OR (6)	1/10/2022	1:54 PM	AP-1	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	28	1176	0.00161	00	42	
OR (7)	1/11/2022	7:05 AM	LL-1	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	3	312	0.00017	00	104	
OR (8)	1/13/2022	12:19 PM	SS-1	DISTRIBUTION UNDERGROUND	PUBLIC	JUNCTION BOX	17	1836	0.00097	00	108	
OR (9)	1/18/2022	11:08 AM	LP-3	DISTRIBUTION UNDERGROUND	EQUIPMENT	CONNECTOR	8	536	0.00046	00	67	
OR (10)	1/20/2022	2:15 AM	SC-3	DISTRIBUTION OVERHEAD	OTHER	CONDUCTOR	1	75	0.00006	00	75	
OR (11)	1/22/2022	1:40 AM	AREA WIDE OUTAGE	TRANSMISSION	POWER SUPPLY	SUBSTATION BREAKER	17211	877761	0.98664	50	51	
OR (12)	2/3/2022	7:53 PM	69KV VALLEY OUTAGE	TRANSMISSION	POWER SUPPLY	CONDUCTOR	8995	344274	0.51565	19	38	
OR (13)	2/8/2022	10:27 AM	SS-2	DISTRIBUTION OVERHEAD	EQUIPMENT	FUSE	10	600	0.00057	00	60	
OR (14)	2/12/2022	10:40 AM	LL-1	DISTRIBUTION OVERHEAD	EQUIPMENT	INSULATOR	3	357	0.00017	00	119	

OR (15)	4/3/2022	8:15 AM	LL-1	DISTRIBUTION OVERHEAD	WEATHER	INSULATOR	4	720	0.00023	00	180
OR (16)	4/10/2022	7:40 AM	LC-3	DISTRIBUTION OVERHEAD	EQUIPMENT	TRANSFORMER	2	286	0.00011	00	143
OR (17)	4/11/2022	11:07 PM	69KV LINE 1 OUTAGE	TRANSMISSION	POWER SUPPLY	SUPPORT STRUCTURE	1237	52929	0.07091	03	42
OR (18)	4/12/2022	9:45 AM	AP-1	DISTRIBUTION OVERHEAD	WEATHER	CONNECTOR	20	460	0.00115	00	23
OR (19)	4/13/2022	11:02 AM	AP-2	DISTRIBUTION UNDERGROUND	PUBLIC	CONDUCTOR	60	11160	0.00344	00	186
OR (20)	3/30/2022	9:00 AM	SS-3	DISTRIBUTION UNDERGROUND	PLANNED	SWITCH	30	3240	0.00172	00	108
OR (21)	4/6/2022	9:00 AM	SS-3	DISTRIBUTION UNDERGROUND	PLANNED	SWITCH	42	3192	0.00241	00	76
OR (22)	4/7/2022	9:00 AM	SS-3	DISTRIBUTION UNDERGROUND	PLANNED	SWITCH	44	4972	0.00252	00	113
OR (23)	5/5/2022	11:52 AM	LL-1	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	379	11370	0.02173	00	30
OR (24)	5/9/2022	1:29 PM	LL-1	DISTRIBUTION OVERHEAD	WILDLIFE	SQUIRREL	379	23498	0.02173	01	62
OR (25)	5/26/2022	11:34 AM	LP-4	DISTRIBUTION OVERHEAD	WILDLIFE	SQUIRREL	1	33	0.00006	00	33
OR (26)	6/8/2022	10:40 AM	SS-1	DISTRIBUTION OVERHEAD	VEGETATION	CUTOUT	3	330	0.00017	00	110
OR (27)	6/8/2022	2:30 PM	AB-3	DISTRIBUTION OVERHEAD	WILDLIFE	CUTOUT	6	360	0.00034	00	60
OR (28)	6/14/2022	2:04 PM	LC-3	DISTRIBUTION OVERHEAD	EQUIPMENT	INSULATOR	856	11984	0.04907	00	14
OR (29)	6/18/2022	12:40 PM	WJ-3	DISTRIBUTION OVERHEAD	PUBLIC	CONDUCTOR	1	120	0.00006	00	120
OR (30)	7/26/2022	1:00 PM	SS-1	DISTRIBUTION OVERHEAD	EQUIPMENT	CUTOUT	8	160	0.00046	00	20
OR (31)	7/28/2022	5:15 PM	AB-1	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	1	90	0.00006	00	90

OR (32)	8/16/2022	8:45 AM	SC-3	DISTRIBUTION OVERHEAD	WILDLIFE	SQUIRREL	4	240	0.00023	00	60	
OR (33)	8/17/2022	5:24 PM	LL-1	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	379	29941	0.02173	01	79	
OR (34)	8/21/2022	12:04 AM	AREA WIDE OUTAGE	TRANSMISSION	POWER SUPPLY	1/0/1900	17444	1500184	1.00000	86	86	X
OR (35)	8/21/2022	7:00 AM	AB-1	DISTRIBUTION OVERHEAD	UNKNOWN	CUTOUT	9	1890	0.00052	00	210	
OR (36)	9/15/2022	11:30 AM	AB-1	DISTRIBUTION OVERHEAD	EQUIPMENT	CUTOUT	3	120	0.00017	00	40	
OR (37)	9/20/2022	6:25 AM	AB-2	DISTRIBUTION UNDERGROUND	EQUIPMENT	CONDUCTOR	2	460	0.00011	00	230	
OR (38)	9/26/2022	6:03 PM	SS-3	TRANSMISSION	WEATHER	SUPPORT STRUCTURE	4977	375048	0.28531	21	75	
OR (39)	10/1/2022	5:15 AM	LP-2	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	1	18405	0.00006	01	18405	
OR (40)	10/11/2022	12:00 PM	LP-3	DISTRIBUTION UNDERGROUND	EQUIPMENT	CONDUCTOR	5	600	0.00029	00	120	
OR (41)	10/12/2022	9:36 PM	LL-1	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	70	6790	0.00401	00	97	
OR (42)	10/13/2022	12:05 AM	LL-1	DISTRIBUTION OVERHEAD	EQUIPMENT	TRANSFORMER	3	690	0.00017	00	230	
OR (43)	10/13/2022	3:24 AM	GREENS CREEK	TRANSMISSION	VEGETATION	CONDUCTOR	1	576	0.00006	00	576	
OR (44)	10/13/2022	6:55 AM	SS-1	TRANSMISSION	VEGETATION	CONDUCTOR	1267	53589	0.07263	03	42	
OR (45)	10/15/2022	10:36 AM	WJ-3	DISTRIBUTION OVERHEAD	EQUIPMENT	TRANSFORMER	2	108	0.00011	00	54	
OR (46)	10/18/2022	7:33 PM	AB-1	DISTRIBUTION OVERHEAD	VEGETATION	CONDUCTOR	55	11110	0.00315	00	202	
OR (47)	11/6/2022	1:30 AM	AP-2	DISTRIBUTION OVERHEAD	EQUIPMENT	TRANSFORMER	6	912	0.00034	00	152	
OR (48)	11/11/2022	11:30 AM	LL-1	DISTRIBUTION OVERHEAD	EQUIPMENT	CONNECTOR	2	300	0.00011	00	150	

OR (49)	11/16/2022	10:47 AM	AREA WIDE OUTAGE	GENERATION	POWER SUPPLY	COMMUNICATION OR AUTOMATION	17433	567314	0.99937	32	32
OR (50)	12/6/2022	10:45 PM	WJ-1	DISTRIBUTION OVERHEAD	EQUIPMENT	CONNECTOR	15	225	0.00086	00	15
OR (51)	12/18/2022	7:15 AM	SC-3	DISTRIBUTION OVERHEAD	EQUIPMENT	FUSE	1	60	0.00006	00	60
OR (52)	12/18/2022	1:50 PM	AB-2	DISTRIBUTION OVERHEAD	EQUIPMENT	TRANSFORMER	1	90	0.00006	00	90
OR (53)	12/20/2022	2:00 PM	LL-1	DISTRIBUTION OVERHEAD	EQUIPMENT	TRANSFORMER	1	4286	0.00006	00	4286
OR (54)	12/27/2022	11:58 AM	C-3	DISTRIBUTION OVERHEAD	EQUIPMENT	TRANSFORMER	3	315	0.00017	00	105